

General Instructions:

The purpose of form TCEQ-20700 Backflow Prevention Assembly Test and Maintenance Report (T&M Form) is to document the results of testing a backflow prevention assembly. The form can be completed in one of two ways:

- 1. The form can be printed and completed by hand, or
- 2. The form can be completed electronically through an electronic medium (tablet, laptop computer, etc.). The yellow areas on the form can be completed electronically.

NOTE: <u>*The form is intended to be completed on-site while testing is occurring.*</u> If the form is completed electronically, the electronic device must also be on-site for proper use of this form.

The form must be printed and signed by the Licensed Tester that performed the work, unless TCEQ approved electronic recording keeping is in use. The hardcopy original must be provided to the Public Water System (PWS) as specified in *Title 30 of the Texas Administrative Code 290.44(h)(4)(c)*.

Specific Instructions:

Please follow the instructions below when completing form TCEQ-20700:

- 1. Check boxes: If completing the form electronically, all check boxes can be selected to make the desired indication. Selecting a box will insert an "X" in the box.
- 2. When performing the test, if the "Initial Test" yields acceptable results, do not complete the "Repairs and Materials Used**" or "Test After Repairs" rows on the form.
- 3. Remarks: If completing the form electronically, the "Remarks" section of the form is expandable, which means the final report can be more than one page. All pages of the T&M Report must be submitted to the water system.
- 4. Testing completed by a licensed tester must be documented on one form. Any follow-up testing performed by a different tester must be documented on a separate form.

Things to remember:

- 1. Differential pressure gauges:
 - a. In order to prevent contamination, gauges used on potable water backflow prevention assemblies must **not** be used to test non-potable backflow prevention assemblies.
 - b. Gauges need to be tested for accuracy annually and that date plus the serial number and other gauge information must be correctly recorded on the form. This allows Public water systems to ensure that the gauges are in compliance.
- 2. Annual testing of backflow prevention assemblies (those installed to protect against health hazards) or differential pressure gauges is to occur no more than 12 months from the last test date.
- 3. A tester's license is based on the testing procedures described in the University of Southern California's 10th edition manual. These procedures are expected to be used when testing backflow prevention assemblies.
- 4. Type II assemblies: This form can only accommodate a Type II assembly with a single check bypass.

Texas Commission on Environmental Quality BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

The following form mu	ist be completed for each	h assembly tested.	A signe	d and dated original m	ust be submitted to the p	oublic water supplier	r for recordkeeping *	purposes:	
NAME OF PWS:		Mason Creek Utility District							
			.010379						
				iinion Dr. Katy, TX 77450					
PWS CONTAC		James	ames Parrott						
ADDRESS OF SERVICE:									
The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters									
and is certified to be operating within acceptable parameters. TYPE OF BACKFLOW PREVENTION ASSEMBLY (BPA):									
□ Reduced	Pressure Principl			Reduced Pressure Principle-Detector (RPBA-D) Type II					
				Double Check-Detector (DCVA-D) Type II Spill Desistant Pressure Vegume Presker (SVP)					
Pressure Vacuum Breaker (PVB)									
Manufacturer: Main: Byp							Bypass:		
Model Number: Main:		Bypas	0		BPA Location:				
Serial Number: Main: Bypass:				BPA Serves:					
Reason for test: New Existing Replacement Old Model/Serial #									
Is the assembly installed in accordance with manufacturer recommendations and/or local codes?									
Is the assembly installed on a non-potable water supply (auxiliary)?									
TEST RESULT					Type II				
ILSI KESULI	Reduced Pressur	e Principle A	ssemh	ly (RPRA)	Assembly	PVB & SVB			
		•	sseme		risseniory				
PASS	DCVA			Relief Valve	Bypass Check	Air Inlet	Air Inlet Check Va		
FAIL D 1 st Check		2 nd Check***			Dypass Check			x valve	
Initial Test	Held at psid	Held at	psid	Opened at	Held at psid	Opened at	psid Held at		
Date:	Closed TightImage: Closed TightImage: Closed TightLeakedImage: Closed TightImage: Closed Tight			psid	Closed Tight	Did not open 🔲 psid			
Time:				Did not	Leaked	Did it fully ope	ly open Leaked 🔲		
				open		Yes 🔲 /No 🔲)			
Repairs and Main:									
Materials									
Used** Bypass:							1		
Test After	Held at psid Held at psid			1	I	Dened at psid Held at			
<u>Repair</u>	Closed Tight	Closed Tigh	nt 🔲	-	Closed		psid		
Date:					Tight 🔲				
Time:	444 Opd 1 1	· 1'			1				
*** 2 nd check: numeric reading required for DCVA only									
Differential pressure gauge used:			CNT	Potable:	Date tested for accuracy :				
Make/Model:			SN:		Date tes	ted for accurac	cy :		
Remarks:									
Company Name:				Licensed Tester Name (Print/Type):					
Company Addre				Name (Signature)):				
puity riduit									
Company Phone			BPAT License #						
				License Expiration Date:					
The above is certified to be true at the time of testing.									

* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC §290.46(B)] ** USE ONLY MANUFACTURER'S REPLACEMENT PARTS